

EC type-examination certificate

Number **T10560** revision 2 Project number SO14202348 Page 1 of 1

Issued by NMi Certin B.V.,

designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable

requirements of Directive 2004/22/EC, to:

Manufacturer Marmara Su Sayaçlari Sanayi ve Ticaret A.Ş.

OSB 26. Cad. No 4

Eskişehir Turkey

Measuring instrument A water meter

Trade mark : Valfex

Type : MRM-KTxxx; MRM-GLxxx; MRM-STxxx; MRM-YTxxx

Measuring Range : See paragraph 1.2 of the description.

Environment classes : M1 / E1

Temperature range water : $+0.1 \,^{\circ}\text{C} / +50 \,^{\circ}\text{C}$ (T50 class meters)

+0,1 °C / +90 °C (T90 class meters)

Temperature range ambient : -10 °C / +55 °C

Destined for the measurement of • : Water

Further properties are described in the annexes:

Description T10560 revision 2;Documentation folder T10560-1.

Valid until + + + + 12 March 2023

Remarks This revision replaces the earlier versions, except for its documentation

folder.

Issuing Authority NMi Certin B.V., Notified Body number 0122

12 June 2014

C. Oosterman

Head Certification Board

NMi Certin B.V. Hugo de Grootplein 1 3314 EG Dordrecht The Netherlands T +31 78 633232 certin@nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The designation of NMi Certin BV.as Notified Body can be verified at http://ec.europa.eu/enterprise/newapproach/nando/

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see www.nmi.nl).

Reproduction of the complete document only is permitted.

