

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer FMG International TR
İkitelli OSB, Başak Bulvarı, Başakşehir San. Sit.
C Blok No:10-12, 34230 Başakşehir/İST.
Turkey

Measuring instrument **A Rotary Displacement Gas Meter**

Type : FMiR
FMiR-Dual

Manufacturer's mark or name : FMG International TR

Destined for the measurement of : Gas volume
Accuracy class : Class 1,0 or 1,5 (see tables under 1.2.1 of the description)

Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T11916 revision 0;
- Documentation folder T11916-1.

Valid until 22 June 2030

Issuing Authority

NMI Certin B.V., Notified Body number 0122

22 June 2020

Certification Board

NMI Certin B.V.
Thijssseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.