

CERTIFICATE

EC-Type examination certificate 09-4006

Authorised representative

Inepro Metering BV

Contact person

D. van der Vaart

Address

P.O. Box 92

Postal code, Place

2450 AB, Leimuiden

Country

The Netherlands

Manufacturer

Shanghai Fengyilong Electronic Co., Ltd.

Address

Room 20D, Building 2, No. 1251, Jiangning Road

Postal code, Place

Shanghai, 200060

Country

Instrument

Electronic single-phase two-wire energy meter

Direct connected

Type

PRO-75A

PRO-75D LCD

Register

Mechanical

1/B

Accuracy Class Measurement range

230 V

10(100) A

50 or 60 Hz

1600 imp./kWh

Temperature range

-10 .. 40 °C

Indoor

Protection Class

The energy meter meets the requirements of Directive 2004/22/EC of the European parliament and the council of 31 March 2004 on measuring instruments.

Certification was based on compliance with the following harmonised standards:

EN 50470-1 (2006)

Electricity metering equipment (a.c.)-part 1: General requirements, tests and test

conditions - Metering equipment (class indexes A, B and C)

EN 50470-3 (2006)

Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for

active energy (class indexes A, B and C)

Valid until

March 16, 2019

The results are recorded in the following annex: test report 2113897-QUA/CAL 09-4006.

KEMA Quality B.V. Arnhem, March 16, 2009

ing. J.H.M. Overbeek Certification manager Notified body number 0344 ir. P.J.J.G. Nabuurs **Managing Director**

Integral publication of this certificate and adjoining reports is allowed.

KEMA Quality B.V. Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem The Netherlands T +31 26 3 56 20 00 F +31 26 3 52 58 00 customer@kema.com www.kema.com Registered Arnhem 09085396