

## **EU-TYPE EXAMINATION CERTIFICATE**

Certificate number 1469-21

Shenzhen Kaifa Technology (Chengdu) Co., Ltd. Manufacturer

Contact person Ms. Sona Qin

Address No.1218 Hezuo Rd., Hi-Tech Development Zone (West)

Postal code, City Chengdu Country China

Production site Shenzhen Kaifa Technology (Chengdu) Co., Ltd.

No.1218 Hezuo Rd., Hi-Tech Development Zone (West) Address

Postal code, City Chengdu Country China

Instrument Electronic three-phase four-wire energy meter.

Direct connected

Connection Three-phase Single-phase

> four-wire two-wire (phase R)

Mark - Type MA309MH4LAT6

Register LCD

Active: B; 1000 imp./kW **Accuracy Class** 

Measurement range 230/400 V 230 V

0,25..5(60) A;

50 Hz

Temperature range

-40 .. 70 °C

Use Indoor, not sensitive to phase sequence

**Protection Class** 

M1, M2, E1 and E2 **Environmental class** 

Registry method Programmable, the meters are delivered as:

Bi-directional method separate registers: received- and delivered energy

of the whole connection is added in separate registers

The energy meters meet the requirements of Directive 2014/32/EU, on the harmonisation of the laws of Member States relating to the making available on the market of measuring instruments (recast).

Certification was based on compliance with the following harmonised standards:

Electricity metering equipment (a.c.)-part 1: General requirements, tests and EN 50470-1:2006

test conditions - Metering equipment (class indexes A, B and C)

EN 50470-3:2006 Electricity metering equipment (a.c.)-part 3: Particular requirements - Static

meters for active energy (class indexes A, B and C)

Valid until 25 January 2032

Based on a non-recurrent examination.

Second revision of this certificate. The results are recorded in the following annex: test report 1615-21 R1.

KEMA B.V.

Bas Nerhoeven Director, High-Voltage

Laboratory

Arnhem, 25 January 2022