

EU-TYPE EXAMINATION CERTIFICATE

Certificate number

1575-21

Manufacturer Contact person Address Postal code, City Country	Shenzhen Kaifa Technology (Chengdu) Co., Ltd. Ms. Sona Qin No.1218 Hezuo Rd., Hi-Tech Development Zone (West) Chengdu China
Production site Address Postal code, City Country	Shenzhen Kaifa Technology (Chengdu) Co., Ltd. No.1218 Hezuo Rd., Hi-Tech Development Zone (West) Chengdu China
Instrument	Electronic single-phase two-wire energy meter. Direct connected
Mark - Type Register Accuracy Class Measurement range	MA110M LCD Active: B - 1000 imp./kWh 230 V 0,255(40) and 0,255(60) A 50 Hz
Temperature range Use Protection Class Environmental class Registry method	-40 +70 °C Indoor II M1, M2, E1 and E2 Programmable, the meters are delivered as: Bi-directional method separate registers: received- and delivered energy is added in separate registers
The energy meters meet the requirements of Directive 2014/32/EU, on the harmonisation of the laws of Member States relating to the making available on the market of measuring instruments (recast).	

Certification was based on compliance with the following harmonised standards: Electricity metering equipment (a.c.)-part 1: General requirements, tests and EN 50470-1:2006 test conditions - Metering equipment (class indexes A, B and C) Electricity metering equipment (a.c.)-part 3: Particular requirements - Static EN 50470-3:2006 meters for active energy (class indexes A, B and C) Valid until 9 December 2031

Based on a non-recurrent examination.

Version 2 of this certificate. The results are recorded in the following annex: test report 1471-21 R1.

KFMA B. Bas Verhoeven

Director, High-Voltage Laboratory

Arnhem, 9 December 2021

Copyright: Only integral reproduction of this Certificate is permitted without written permission from KEMA Labs, a CESI brand.