

EU-TYPE EXAMINATION CERTIFICATE

Certificate number 1609-21

Manufacturer Shenzhen Star Instrument Co., Ltd.

Contact person Mrs Li Wang

Address Star Industry Park, Baolong Industry City, Longgang District

Postal code, City 518116, Shenzhen

Country China

Production site Shenzhen Star Instrument Co., Ltd.

Address Star Industry Park, Baolong Industry City, Longgang District

Postal code, City 518116, Shenzhen

Country China

Instrument Electronic single-phase two-wire two-element energy meter. Direct connected

Mark - Type DDS26D, STZ131

Register LCD

Accuracy Class Active: C and B

Measurement range 220-240 V, 0,15 – 5(80) and 0,15 – 5(100) A, 50 Hz

Temperature range -40 .. 70 °C Use Outdoor

Protection Class _____I

Environmental class M1, M2, E1 and E2

Registry method Bi-directional method separate registers: received- and delivered energy of the

whole connection is added in separate registers

The energy meters meet the requirements of Directive 2014/32/EU, on the harmonisation of the laws of Member States relating to the making available on the market of measuring instruments (recast).

Certification was based on compliance with the following harmonised standards:

EN 50470-1:2006 Electricity metering equipment (a.c.)-part 1: General requirements, tests and

test conditions - Metering equipment (class indexes A, B and C)

EN 50470-3:2006 Electricity metering equipment (a.c.)-part 3: Particular requirements - Static

meters for active energy (class indexes A, B and C)

Valid until 13 December 2031

Based on a non-recurrent examination.

Version 1 of this certificate. The results are recorded in the following annex: test report 1608-21 RO.

KEMA B.V.

Bas Verhoeven Director, High-Voltage

Laboratory

Arnhem, 13 December 2021