

## **EU-TYPE EXAMINATION CERTIFICATE**

Certificate number 1737-18

Shenzhen Kaifa Technology (Chengdu) Co., Ltd. Manufacturer

Contact person Ms. Sona Qin

Address No.1218 Hezuo Rd., Hi-Tech Development Zone (West)

Postal code, City Chengdu Country China

Production site Shenzhen Kaifa Technology (Chengdu) Co., Ltd.

No.1218 Hezuo Rd., Hi-Tech Development Zone (West) Address

Postal code, City Chengdu China Country

Electronic single-phase two-wire, energy meter Instrument

Direct connected

MA110M Mark - Type Register LCD

**Accuracy Class** Active: 1/B - 1000 imp./kWh

indoor

Reactive: 2 - 1000 imp./kvarh

230 V, 0,25..5(60) A, 50 Hz Measurement range -40 .. 70 °C

Ш

Temperature range

Use

**Protection Class** 

**Environmental class** M1, M2, E1 and E2

Registry method Programmable, the meters are delivered as:

Bi-directional method separate registers: received- and delivered energy is

added in separate registers

The energy meters meet the requirements of Directive 2014/32/EU, on the harmonisation of the laws of Member States relating to the making available on the market of measuring instruments (recast).

Certification was based on compliance with the following harmonised standards:

EN 50470-1:2006 Electricity metering equipment (a.c.)-part 1: General requirements, tests and

test conditions - Metering equipment (class indexes A, B and C)

EN 50470-3:2006 Electricity metering equipment (a.c.)-part 3: Particular requirements - Static

meters for active energy (class indexes A, B and C)

Valid until 24 January 2034

Based on a non-recurrent examination.

Sixth revision of this certificate. The results are recorded in the following annex: test report 1503-22 RO.

KEMA B.V.

Bas Nerhoeven

Director, High-Voltage

Laboratory

Arnhem, 24 January 2022