DNV-GL

EU-TYPE EXAMINATION CERTIFICATE

Certificate number 1002-19

Manufacturer Wasion Group Limited Contact person Mr. Penglong Li

Address No.468 Tongzipo West Road, Wasion Science Park

Postal code, City 410205 Changsha

Country China

Production site Wasion Group Limited

Address No.468 Tongzipo West Road, Wasion Science Park

Postal code, City 410205 Changsha

Country China

Instrument Electronic single-phase two-wire, energy meter

Direct connected

Mark - Type aMeter100

Register LCD

Accuracy Class Active: 1/B

Reactive: 2

Measurement range 220-240 V

5(80) A, 5(60)A or 10(60)A

50 Hz

active: 1000 imp./kWh reactive: 1000 imp./kvarh

Temperature range -40 .. 70 °C Use Indoor

Protection Class II

Environmental class M1, E1 and E2

Registry method Bi-directional method separate registers: received- and delivered energy of

the whole connection is added in separate registers

The energy meters meet the requirements of Directive 2014/32/EU, on the harmonisation of the laws of Member States relating to the making available on the market of measuring instruments (recast).

Certification was based on compliance with the following harmonised standards:

EN 50470-1:2006 Electricity metering equipment (a.c.)-part 1: General requirements, tests

and test conditions - Metering equipment (class indexes A, B and C)

EN 50470-3:2006 Electricity metering equipment (a.c.)-part 3: Particular requirements - Static

meters for active energy (class indexes A, B and C)

Valid until 28 May 2029

Based on a non-recurrent examination.

Version 2 of this certificate. The results are recorded in the following

annex: test report 1272-19 V1.

KEMA B.V.

Bas Verhoeven

Director, High-Voltage

Laboratory

Arnhem, 13 June 2019



Copyright: Only integral reproduction of this Certificate is permitted without written permission from DNV GL.