

EU-TYPE EXAMINATION CERTIFICATE

Certificate number	1189-18
Manufacturer	ZIV Metering Solutions S.L.
Contact person	Ms. Cristina Martinez
Address	Parque Tecnológico, 210
Postal code, City	48170 Zamudio
Country	Spain
Production site	ZIV Metering Solutions S.L.
Address	Parque Tecnológico, 210
Postal code, City	48170 Zamudio
Country	Spain
Instrument	Electronic three-phase four-wire energy meter Direct connected
Mark - Type	5CTA3BCE000AAD0
Register	LCD
Accuracy Class	Active: 2/A
Measurement range	230/400 V; 0,25..5(100) A; 50 Hz active : 1000 imp./kWh
Temperature range	-25 .. +70 °C
Use	Indoor, not sensitive to phase sequence
Protection Class	II
Environmental class	M1, E1 and E2
Registry method	Bi-directional method separate registers: received- and delivered energy of the whole connection is added in separate registers

The energy meters meet the requirements of Directive 2014/32/EU, on the harmonisation of the laws of Member States relating to the making available on the market of measuring instruments (recast).

Certification was based on compliance with the following harmonised standards:

EN 50470-1:2006	Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
EN 50470-3:2006	Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)

Valid until 12 June 2028

Based on a non-recurrent examination.

Version 1 of this certificate. The results are recorded in the following annex: test report 1188-18.

DNV GL Netherlands B.V.



J.P. Fonteijne
Executive Vice President
KEMA Laboratories



Arnhem, 12 June 2018

Copyright: Only integral reproduction of this Certificate is permitted without written permission from DNV GL.

DNV GL Netherlands B.V. Utrechtseweg 310, 6812 AR Arnhem, P.O. Box 9035, 6800 ET Arnhem, the Netherlands
Notified body number 2290