

EU-TYPE EXAMINATION CERTIFICATE

Certificate number	1434-17
Manufacturer	Holley Technology Ltd.
Contact person	Ms. Xiaofang Liu
Address	No. 181 Wuchang Avenue, Yuhang district
Postal code, City	310023 Hangzhou
Country	China
Production site	Holley Technology Ltd.
Address	No. 181 Wuchang Avenue, Yuhang district
Postal code, City	310023 Hangzhou
Country	China
Instrument	Electronic three-phase four-wire energy meter. Transformer connected
Mark - Type	DTS541
Register	LCD
Accuracy Class	Active: C; Reactive: 2
Measurement range	3x230/400 V, 3x0,01..1(10) A, 50 Hz Active: 10000 imp./kWh; Reactive: 10000 imp./kvarh
Temperature range	-40..70 °C
Use	Indoor, not sensitive to phase sequence
Protection Class	II
Environmental class	M1, E1 and E2
Registry method	Bi-directional method separate registers: received- and delivered energy of the whole connection is added in separate registers

The energy meters meet the requirements of Directive 2014/32/EU, on the harmonisation of the laws of Member States relating to the making available on the market of measuring instruments (recast).

Certification was based on compliance with the following harmonised standards:

EN 50470-1 (2006)	Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
EN 50470-3 (2006)	Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)
Valid until	8 September 2027

Based on a non-recurrent examination.

Version 1 of this certificate. The results are recorded in the following annex: test report 1433-17.

DNV GL Netherlands B.V..



J.P. Fonteijne
Executive Vice President
KEMA Laboratories



Arnhem, 8 September 2017

Copyright: Only integral reproduction of this Certificate is permitted without written permission from DNV GL.