

EU-TYPE EXAMINATION CERTIFICATE

Certificate number	1543-17
Manufacturer	NARI Technology Co., Ltd
Contact person	Mr. Yongsheng He
Address	No. 19 Chengxin Avenue, Nanjing
Country	China
Production site	NARI Technology Co., Ltd
Address	No.19 Chengxin Avenue, Nanjing
Country	China
Instrument	Electronic single-phase two-wire, two-element energy meter. Direct connected
Mark - Type	DDZY1339
Register	LCD
Accuracy Class	Active: 1/B; Reactive: 2
Measurement range	230 V, 5(100) A, 50 Hz active: 1200 imp./kWh; reactive: 1200 imp./kvarh
Temperature range	-40...70 °C
Use	Indoor
Protection Class	II
Environmental class	M1, E1 and E2
Registry method	Bi-directional method separate registers: received- and delivered energy of the whole connection is added in separate registers.

The energy meters meet the requirements of Directive 2014/32/EU, on the harmonisation of the laws of Member States relating to the making available on the market of measuring instruments (recast).

Certification was based on compliance with the following harmonised standards:

EN 50470-1 (2006)	Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
EN 50470-3 (2006)	Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)
Valid until	10 November 2027

Based on a non-recurrent examination.

Version 1 of this certificate. The results are recorded in the following annex: test report 1542-17.

DNV GL Netherlands B.V.



J.P. Fonteijne
Executive Vice President
KEMA Laboratories



Arnhem, 10 November 2017

Copyright: Only integral reproduction of this Certificate is permitted without written permission from DNV GL.