DNV·GL

EU-TYPE EXAMINATION CERTIFICATE

Certificate number 1739-18

Country

Manufacturer Elster Solutions GmbH Contact person Mr Morar Bogdan Address Steinern Str. 19-21 Postal code, City Mainz-Kastel

Germany

Production site Elster Solutions GmbH Elster Rometrics S.R.L

Steinern Str. 19-21 Address Timisoara Airport Park , DJ 691

Km8+775m, Judet Timis

Mainz-Kastel Postal code, City Giarmata, 300210

Country Germany Romania

Instrument Electronic three-phase four-wire energy meter.

Direct connected

Connection Three-phase Single-phase

> four-wire two-wire (phase L1)

Mark - Type HS3300SH4LAT1 and

Register

Accuracy Class Active: 1/B - 1000 imp./kWh; Reactive: 2 - 1000 imp./kvarh

Measurement range 230/400 V 230 V

0,25..5(60) A; 50 Hz

-40 .. 70 °C Temperature range

Indoor, not sensitive to phase sequence

Protection Class

Environmental class M1, E1 and E2

Registry method Programmable, the meters are delivered as:

Bi-directional method separate registers: received- and delivered energy of

the whole connection is added in separate registers

The energy meters meet the requirements of Directive 2014/32/EU, on the harmonisation of the laws of Member States relating to the making available on the market of measuring instruments (recast).

Certification was based on compliance with the following harmonised standards:

EN 50470-1:2006 Electricity metering equipment (a.c.)-part 1: General requirements, tests

and test conditions - Metering equipment (class indexes A, B and C)

EN 50470-3:2006 Electricity metering equipment (a.c.)-part 3: Particular requirements - Static

meters for active energy (class indexes A, B and C)

Valid until 10 December 2028

Based on a non-recurrent examination.

Version 3 of this certificate. The results are recorded in the following

annex: test report 1130-19 V2.

KEMA

KFMA B.\

Bas Nerhoeven

Director, High-Voltage

Laboratory

Laboratories Arnhem, 26 April 2019

Copyright: Only integral reproduction of this Certificate is permitted without written permission from KEMA B.V.