



CERTIFICATE

EC-Type examination certificate 6389-10

Authorised representative	: SC Elster Rometrics SRL
Contact person	: Marcel Blocu
Address	: DN 6 Lugoj-Timisoara, km 551+330 m
Postal code, Place	: Ghiroda, 307200, Judetul Timis
Country	: Romania
Manufacturer	: SC Elster Rometrics SRL Forth Corporation Public Co., Elster Electricity, LLC LTD.
Address	: DN 6 Lugoj-Timisoara, km 77 moo11 Phuttamonton 5 208 South Rogers Lane : 551+330 m Road, Raikhing Sampran NC 27610, Raleigh Ghiroda, 307200, Judetul District Timis Nakronpratom
Country	: Romania Thailand U.S.A.
Instrument	: Electronic three-phase four-wire energy meter Transformer connected Three-phase four-wire three-phase three-wire
Type	: A1800
Register	: LCD
Accuracy Class	: 0,2S, 0,5S, 1, C, B and A
Measurement range	: 58/100 .. 240/415 V 100 .. 240 V 1(10) A or 5(20) A 50 or 60 Hz 5000 imp./kWh
Temperature range	: -25..55 °C
Use	: Indoor
Protection Class	: II
Environmental class	: M1, E2
Registry method	: programmable

The energy meter meets the requirements of Directive 2004/22/EC of the European parliament and the council of 31 March 2004 on measuring instruments.


Certification was based on compliance with the following harmonised standards:

- EN 50470-1 (2006) : Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
- EN 50470-3 (2006) : Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)

Valid until : October 29, 2020

The results are recorded in the following annex: test report 70068174-TDT 6389-10.

KEMA T&D Testing Services - Calibration and Metering
Arnhem, October 29, 2010


ir. A.P.M. Baars
Certification manager
Notified body number 0344


ir. P.J.J.G. Nabuurs
Managing Director

The investigation reported here does not confer any right to use an approbation mark granted by KEMA.

Integral publication of this certificate and adjoining reports is allowed.
This certificate is issued provided that neither KEMA nor the RvA assumes any liability.

KEMA Nederland B.V. Utrechtseweg 310, 6812 AR Arnhem, The Netherlands P.O. Box 9035, 6800 ET Arnhem, The Netherlands
T +31 (0)26 3 56 2215 F +31 (0)26 4 42 6211 C&M@kema.com www.kema.com trade register Arnhem 09080262

Experience you can trust.