



# CERTIFICATE

## EC-Type examination certificate 6399-10

Manufacturer : Powercom Ltd.  
Contact person : Mr. Yackov Dar  
Address : Building 268  
Postal code, Place : 44930, Kibbutz Ramat Hakovesh  
Country : Israel

Production site : Shanghai Xielin Electronic Co., Ltd.  
Address : No. 505, Jinbi Road, Fengxian District  
Postal code, Place : 201404, Shanghai  
Country : China

Instrument : Electronic three-phase four-wire energy meter  
Direct connected

Mark - Type : PCR423  
Register : LCD  
Accuracy Class : 1 / B  
Measurement range : 220/380 V  
1..20(80) A  
50 Hz  
400 imp./kWh

Temperature range : -25..55 °C  
Use : Indoor  
Protection Class : II  
Environmental class : M1, E2  
Registry method : programmable

---

The energy meter meets the requirements of Directive 2004/22/EC of the European parliament and the council of 31 March 2004 on measuring instruments.

Certification was based on compliance with the following harmonised standards:

EN 50470-1 (2006) : Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)  
EN 50470-3 (2006) : Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)


Valid until : January 6, 2021

Based on a non-recurrent examination.

---

Version 2 of this certificate. The results are recorded in the following annex: test report TIC 7065-14.

KEMA Nederland B.V.  
Arnhem, 22 January 2015

  
ing. S.A.M. Verhoeven  
Business Line Director Testing, Inspections & Certification  
Notified body number 2290