

CERTIFICATE

EC-Type examination certificate 6404-10

Manufacturer : NationPower AG
Contact person : Mr. Yaniv Oren
Address : Churerstrasse. 108
Postal code, Place : 8808 Pfäffikon
Country : Switzerland

Production site : Shanghai Xielin Electronic Co., Ltd.
Address : No. 505, Jinbi Road, Fengxian District
Postal code, Place : 201404, Shanghai
Country : China

Instrument : Electronic three-phase four-wire energy meter
Direct connected

Mark - Type : PCR423
Register : LCD
Accuracy Class : 1 / B
Measurement range : 220/380 V
1..20(80) A
50 Hz
400 imp./kWh

Temperature range : -25..55 °C
Use : Indoor
Protection Class : II
Environmental class : M1, E2
Registry method : programmable

The energy meter meets the requirements of Directive 2004/22/EC of the European parliament and the council of 31 March 2004 on measuring instruments.


Certification was based on compliance with the following harmonised standards:


EN 50470-1 (2006) : Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
EN 50470-3 (2006) : Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)

Valid until : December 31, 2020

The results are recorded in the following annex: test report 70068190-QUA/CAL 6404-10.

KEMA Quality BV - Calibration
Arnhem, December 31, 2010


Ir. A.P.M. Baars
Certification manager
Notified body number 0344


Ir. P.J.J.G. Nabuurs
Managing Director

The investigation reported here does not confer any right to use an approbation mark granted by KEMA.

Integral publication of this certificate and adjoining reports is allowed.
This certificate is issued provided that neither KEMA nor the RvA assumes any liability.