

CERTIFICATE

EC-Type examination certificate 6972-12

| | | |
|---------------------|---|--|
| Manufacturer | : Inepro Metering BV | |
| Contact person | : D. van der Vaart | |
| Address | : Pondweg 7 | |
| Postal code, Place | : 2153PK Nieuw-Vennep | |
| Country | : The Netherlands | |
| Production site | : Shanghai Fengyilong Electronic Co., Ltd. | Jiangsu Liyang Electric Instrument Co., Ltd. |
| Address | : Room 20D, Building 2, No. 1251, Jiangning Road | Xinchang Town, Liyang City |
| Postal code, Place | : Shanghai, 200060 | Jiangsu, 213372 |
| Country | : China | China |
| Instrument | : Electronic three-phase four-wire energy meter Direct connected | |
| Mark - Type | : YL3-65A and YL3-65A M-bus | |
| Register | : LCD | |
| Accuracy Class | : 1 / B | |
| Measurement range | : 230/400 V 10(65) A 50 and 60 Hz 400 imp./kWh | |
| Temperature range | : -25..55 °C | |
| Use | : Indoor, not sensitive to phase sequence | |
| Protection Class | : II | |
| Environmental class | : M1, E2 | |
| Registry method | : Programmable | |

The energy meter meets the requirements of Directive 2004/22/EC of the European parliament and the council of 31 March 2004 on measuring instruments.

Certification was based on compliance with the following harmonised standards:

- EN 50470-1 (2006) : Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
- EN 50470-3 (2006) : Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)

Valid until : May 15, 2022

Based on a non-recurrent examination.

The results are recorded in the following annex: test report 72140558-TIC 6972-12.

KEMA Nederland B.V. - Calibration & Metering
Arnhem, May 15, 2012

Ing. M. Thuis
Certification manager
Notified body number 2290

The investigation reported here does not confer any right to use an approbation mark granted by KEMA.

Integral publication of this certificate and adjoining reports is allowed.
This certificate is issued provided that neither KEMA nor the RvA assumes any liability.

KEMA Nederland B.V. Utrechtseweg 310, 6812 AR Arnhem, The Netherlands P.O. Box 9035, 6800 ET Arnhem, The Netherlands
T +31 (0)26 3 56 2215 F +31 (0)26 4 42 6211 C&M@kema.com www.kema.com trade register Arnhem 09080262



ing. S.A.M. Verhoeven
Director Testing, Inspections & Certification