

CERTIFICATE

TYPE TEST OF ENERGY METERS

Manufacturer : Inepro Metering BV
Contact person : D. van der Vaart
Address : Pondweg 7
Postal code, Place : 2153PK, Nieuw-Venep
Country : The Netherlands

Production site : Zhejiang Yongtailong Electronic Co., Ltd.
Address : No. 320 Tongsheng Road, Tongxiang
Postal code, Place : 314500, Jiaxing City, Zhejiang
Country : China

Instrument : Electronic single-phase two-wire energy meter
Direct connected

Mark - Type : PRO1-S, PRO1-2T, PRO1-Mb and PRO1-Mod
Register : LCD
Accuracy Class : 1 / B
Measurement range : 230 V
5(45) A
50 Hz
10000 imp./kWh

Use : Indoor
Protection Class : II
Registry method : Programmable

The energy meter meets the requirements of:

IEC 62052-11 (2003) : Electricity metering equipment (a.c.) - General requirements, tests and test conditions - Metering equipment


IEC 62053-21 (2003) : Electricity metering equipment (a.c.) - Static meters for active energy (classes 1 and 2)

Based on a non-recurrent examination.

The results are recorded in our test report with reference 72141340 -TIC 7017-14.

KEMA Nederland B.V. - Calibration & Metering
Arnhem, 16 July 2014


ing. M. Achterkamp
Certification manager


ing. S.A.M. Verhoeven
Business Line Director Testing, Inspections & Certification
Certificate nr. 72141340 -TIC 7017-14C

The investigation reported here does not confer any right to use an approbation mark granted by DNV KEMA.

Integral publication of this certificate and adjoining reports is allowed.
This certificate is issued provided that neither DNV KEMA nor the RvA assumes any liability.