

CERTIFICATE

EC-Type examination certificate 7030-12

Manufacturer : Microstar Electric Company Limited
Contact person : Changchun Yang
Address : 10 Dajiang Road
Postal code, Place : 210039 Nanjing
Country : China

Production site : Microstar Electric Company Limited
Address : 10 Dajiang Road
Postal code, Place : 210039 Nanjing
Country : China

Instrument : Electronic three-phase four-wire energy meter
Direct connected

Mark - Type : P 2000-D
Register : LCD
Accuracy Class : 1 / C
Measurement range : 90/157 to 240/415 V
10(160) A
50 or 60 Hz
200 imp./kWh

Temperature range : -25..55 °C
Use : Indoor
Protection Class : II
Environmental class : M1, E2
Registry method : bi-directional method separate registers: received- and delivered energy of the whole connection is added in separate registers.

The energy meter meets the requirements of Directive 2004/22/EC of the European parliament and the council of 31 March 2004 on measuring instruments.

Certification was based on compliance with the following harmonised standards:


EN 50470-1 (2006) : Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
EN 50470-3 (2006) : Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)

Valid until : 7 November 2022

Based on a non-recurrent examination.

The results are recorded in the following annex: test report 72141147 -TIC 7030-12.

KEMA Nederland B.V. - Calibration & Metering
Arnhem, 7 November 2012


ing. R.F. Garssen
Certification manager
Notified body number 2290


ing. S.A.M. Verhoeven
Director Testing, Inspections & Certification

The investigation reported here does not confer any right to use an approbation mark granted by KEMA.

Integral publication of this certificate and adjoining reports is allowed.
This certificate is issued provided that neither KEMA nor the RvA assumes any liability.