

CERTIFICATE

EC-Type examination certificate 7068-13

Manufacturer	: ZIV Metering Solutions S.L.
Contact person	: Ms. Cristina Martinez
Address	: Parque Tecnológico, 210
Postal code, Place	: 48170 Zamudio
Country	: Spain
Production site	: ZIV Metering Solutions S.L.
Address	: Parque Tecnológico, 210
Postal code, Place	: 48170 Zamudio
Country	: Spain
Instrument	: Electronic single-phase two-wire energy meter Direct connected
Mark - Type	: 5CTME2C477
Register	: LCD
Accuracy Class	: B (Wh), 2 (varh)
Measurement range	: 127 - 230 V 0,25..5(80) A 50 Hz 1000 imp./kWh
Temperature range	: -25..70 °C
Use	: Indoor
Protection Class	: II
Environmental class	: M1, E1
Registry method	: Bi-directional method separate registers: received- and delivered energy of the whole connection is added in separate registers

The energy meter meets the requirements of Directive 2004/22/EC of the European parliament and the council of 31 March 2004 on measuring instruments.

Certification was based on compliance with the following harmonised standards:


EN 50470-1 (2006)	: Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
EN 50470-3 (2006)	: Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)

Valid until : 18 November 2023

Based on a non-recurrent examination.

The results are recorded in the following annex: test report 72141184-TIC 7068-13.

KEMA Nederland B.V. - Calibration & Metering
Arnhem, 18 November 2013


ir. A.P.M. Baars
Certification manager
Notified body number 2290


Ing. S.A.M. Verhoeven
Business Line Director Testing, Inspections & Certification

The investigation reported here does not confer any right to use an approbation mark granted by DNV KEMA.

Integral publication of this certificate and adjoining reports is allowed,
This certificate is issued provided that DNV KEMA not assumes any liability.