

EC type-examination certificate

Number **T10012** revision 5 Project number SO13200657 Page 1 of 1

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:	
Manufacturer	ABB AB Arnöleden 2 SE-611 31 Nyköping SWEDEN	
Measuring instrument	A static Active Electrical Energy Meter	
	Туре	: FB.11. and HB.11. (DELTAsingle)
	Reference voltage Reference current Destined for the measurement of Accuracy class Environment classes Temperature range Further properties are described in – Description T10012 revision 5	 : 230 V : 10 A : electrical energy, in a - single-phase two-wire network : A or B : M2 / E2 : -40 °C / +70 °C
	– Documentation folder T10012-4	
Valid until	15 February 2017	
Remarks	This revision replaces the earlier ve folder.	ersions, including its documentation
Issuing Authority	NMi Certin B.V., Notified Body	number 0122
NMi Certin B.V. Hugo de Grootplein 1 3314 EG Dordrecht The Netherlands T +31 78 6332332	12 February 2013 C. Oosterman Head Certification Board This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability. The designation of NMi Certin B.V. as Notified	Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see www.nmi.nl).
certin@nmi.nl www.nmi.nl	Body can be verified at http:// ec.europa.eu/enterprise/newapproach/nando/	Reproduction of the complete document only is permitted.