

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis+Gyr AG
Theilerstrasse 1
CH 6301 Zug
Switzerland

Measuring instrument **A static Active Electrical Energy Meter**

Type : ZMG300/400... (S2); ZFG400...

Manufacturer's mark or name : Landis+Gyr

Reference voltage : 3x57,7/100 V – 3x277/480 V

Reference current : ZMG300 5, 10, 15 or 20 A
Z.G400 1, 2 or 5 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- two-phase three-wire network
- single-phase two-wire network

Accuracy class : ZMG300 A or B
Z.G400 B or C

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
– Description T10034 revision 19;
– Documentation folder T10034-7.

Valid until 6 February 2027

Remark This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
5 November 2019

Certification Board

NMI Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.