

Issued by NMI Certin B.V.,
 designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:

Manufacturer Itron - Ganz Meter Company Ltd.
 Táncsics Mihály 11
 H-2100 Gödöllő
 Hungary

Measuring instrument An electromechanical **Active Electrical Energy Meter**

Type : C114 / B114

Reference voltage : 3x230/400 V (C114) or 3x230 V (B114)

Reference current : 5, 10 or 20 A

Destined for the measurement of : electrical energy, in a
 - three-phase three-wire network
 - three-phase four-wire network

Accuracy class : A

Environment classes : M1 / E2

Temperature range : -25 °C / +70 °C

Further properties are described in the annexes:
 – Description T10037 revision 7;
 – Documentation folder T10037-7.

Valid until 23 November 2016

Remarks This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
 18 February 2013

C. Oosterman
 Head Certification Board

NMI Certin B.V.
 Hugo de Grootplein 1
 3314 EG Dordrecht
 The Netherlands
 T +31 78 6332332
 certin@nmi.nl
 www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The designation of NMI Certin BV.as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMI (see www.nmi.nl).

Reproduction of the complete document only is permitted.