



# EU-type examination certificate

Number **T10037** revision 9  
Project number SO16202552  
Page 1 of 1

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	Itron - Ganz Meter Company Ltd. Táncsics Mihály 11 H-2100 Gödöllő Hungary
Measuring instrument	A electromechanical <b>Active Electrical Energy Meter</b> Type : C114 / B114 Reference voltage : 3x230/400 V (C114) or 3x230 V (B114) Reference current : 5, 10 or 20 A Destined for the measurement of : electrical energy, in a - three-phase three-wire network - three-phase four-wire network Accuracy class : A Environment classes : M1 / E2 Temperature range : -25 °C / +70 °C Type : C114 / B114  Further properties are described in the annexes: - Description T10037 revision 9; - Documentation folder T10037-8.
Valid until	23 November 2026
Remarks	This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**  
13 January 2017

  
C. Oosterman  
Head Certification Board

**NMi Certin B.V.**  
Hugo de Grootplein 1  
3314 EG Dordrecht  
The Netherlands  
T +31 78 6332332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Reproduction of the complete document only is permitted.

