

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	Itron – Ganz Meter Company Ltd. Tancsics Mihály 11 H-2100 Gödöllő Hungary
Measuring instrument	An electromechanical Active Electrical Energy Meter Type : S16X, H10, A49 or MX2 (country dependent) Reference voltage : 230 V Reference current : 5 or 10 A Destined for the measurement of : electrical energy, in a - single-phase two-wire network Accuracy class : A Environment classes : M1 / E2 Temperature range : -25 °C / +70 °C Further properties are described in the annexes: – Description T10038 revision 6; – Documentation folder T10038-5.
Valid until	21 November 2016
Remarks	This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
16 December 2013


C. Oosterman
Head Certification Board