

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity modules mentioned in article 9 of Directive 2004/22/EC, after  
having established that the Measuring instrument meets the applicable  
requirements of Directive 2004/22/EC, to:

Manufacturer Itron  
Langer Road, Felixstowe  
Suffolk IP11 2ER  
England

Measuring instrument **A static Active Electrical Energy Meter**

Type : ACE3000 type 260  
Brand : Actaris or Itron

Reference voltage : 3x230/400 V or  
3x120/208 V

Reference current : 5, 10 or 20A

Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- three-phase three-wire network  
- two-phase three-wire network  
- single-phase two-wire network

Accuracy class : - three-phase three-wire  
measurements: class A  
- all other applications: class A or B

Environment classes : M1 / E2


Temperature range : -40 °C / +70 °C

Further properties are described in the annexes  
– Description T10039 revision 5  
– Documentation folder T10039-3

Valid until 8 January 2017

Remarks This revision replaces the earlier versions, except for its documentation  
folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
22 December 2011



C. Oosterman  
Head Certification Board