

Issued by NMI Certin B.V.  
Hugo de Grootplein 1  
3314 EG Dordrecht  
The Netherlands

In accordance with The "Metrologiewet" (Stb. 2006, 137) as Dutch implementation of Directive 2004/22/EC on measuring instruments (MID).

Manufacturer Stepper Energie France  
51 Rue Jaques Mugnier – B.P. 2154  
68060 Mulhouse Cedex  
France

In respect of A model of a static **Active Electrical Energy Meter**

Type : (M)DVS40

Characteristics Reference voltage : 3 x 230/400 V  
Reference current : MDVS40 1 or 5 A  
DVS40 5 or 10 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
Accuracy class : A or B  
Mechanical environment class : M1  
Electromagnetic environment class : E2  
Temperature range : MDVS40 -25°C / +70°C  
DVS40 -40°C / +70°C

In the description number T10046 revision 1 further characteristics are described.

Valid until 2 April 2017

Description and documentation The instrument is described in the description number T10046 revision 1 and documented in the documentation folder T10046-1, appertaining to this EC-type examination certificate.

Remark This revision replaces the earlier version, except for the documentation folder.

The Notified Body number 0122  
NMI Certin, 2 October 2009

  
C. Oosterman  
Head Certification Board