

Issued by NMI Certin B.V.,
appointed and approved by the Secretary of State to perform tasks with respect to conformity modules mentioned in regulation 39 of the Measuring Instruments Regulations 2016 as amended, after having established that the measuring instrument meets the applicable requirements of the Measuring Instruments Regulations 2016 as amended, to:

Manufacturer EMH metering GmbH & Co. KG
Neu-Galliner Weg 1
19258 Gallin
Germany

Measuring instrument A static **Active Electrical Energy Meter**
Type : LZQJ-XC, STMJ-XC, DMTZ-XC, ESM-XC, EDLZ and XC-RACK as direct connected meter (DCM) and transformer connected meter (TCM)

Manufacturer's mark or name : EMH

Reference voltage : 3x57,7/100 V...3x400/690 V (TCM)
3x100 V...3x690 V (TCM)
3x290/500 V...3x400/690 V (TCM)
3x220/380 V...3x240/415 V (DCM)

Reference current : 1 A, 2,5 A or 5 A (TCM)
5 A or 10 A (DCM)

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- two-phase three-wire network
- single-phase two-wire network

Accuracy class : B or C (TCM)
A or B (DCM)

Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
- Description T10068 revision 37;
- Documentation folder T10068-25.

Valid until 25 July 2027
Initially issued 25 July 2017

Remark This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
31 January 2024

Certification Board