

Issued by NMi Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity modules mentioned in article 9 of Directive 2004/22/EC, after  
having established that the Measuring instrument meets the applicable  
requirements of Directive 2004/22/EC, to:

Manufacturer Networked Energy Services Corporation  
550 Meridian Avenue  
San Jose, CA 95126  
United States of America

Measuring instrument A static **Active Electrical Energy Meter**  
Type : 83330-3xxxx  
Reference voltage : 3x230/400 V  
Reference current : 5 or 10 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- two-phase three-wire network  
- single-phase two-wire network  
Accuracy class : A or B  
Environment classes : M2 / E2  
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10072 revision 9;
- Documentation folder T10072-3.

Valid until 7 August 2017

Remarks This revision replaces the earlier versions, except for its documentation  
folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**  
23 November 2015

  
C. Oosterman  
Head Certification Board