

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	Landis+Gyr 1 Lysander Drive, Northfields Industrial Estate Market Deeping, Peterborough, PE6 8FB England
Measuring instrument	A static Active Electrical Energy Meter Type : E120LiME Reference voltage : 3 x 230/400 V, 3 x 230 V or 230 V Reference current : 5 or 10 A (DC version) 5 A (CT version) Destined for the measurement of : Electrical energy, in a - Three-phase four-wire network - Three-phase three-wire network - Two-phase three-wire network - Single-phase two-wire network Accuracy class : A or B C (only CT version) Environment classes : M1 / E2 Temperature range : -40°C / +70°C Further properties are described in the annexes - Description T10087 revision 4 - Documentation folder T10087-3
Valid until	17 March 2020
Remark	This revision replaces the earlier versions, except for its documentation folder.
Issuing Authority	NMi Certin B.V., Notified Body number 0122 3 February 2012


C. Oosterman
Head Certification Board