

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	Iskraemeco Savska loka 4 4000 Kranj Slovenia
Measuring instrument	A static Active Electrical Energy Meter Type : ME371 or ME372 or ME374 Reference voltage : 230 V Reference current : 5 or 10 A Destined for the measurement of : electrical energy, in a - single-phase two-wire network Accuracy class : A or B Environment classes : M1 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes: – Description T10115 revision 5; – Documentation folder T10115-6.
Valid until	5 March 2018
Remarks	This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
26 March 2015


C. Oosterman
Head Certification Board