

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Networked Energy Services
5215 Hellyer Avenue, Suite 150
San Jose, CA 95138
United States of America

Measuring instrument A static **Active Electrical Energy Meter**

Type	: 83331-1xxxx
Reference voltage	: 230 V
Reference current	: 5 or 10 A
Destined for the measurement of	: electrical energy, in a - single-phase two-wire network
Accuracy class	: A or B
Environment classes	: M2 / E2
Temperature range	: -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10146 revision 17;
- Documentation folder T10146-4.

Valid until 22 September 2028

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority

NMI Certin B.V., Notified Body number 0122
12 March 2019


C. Oosterman
Head Certification Board