

EU-type examination certificate

Number **T10156** revision 6 Project number 1901835 Page 1 of 1

Issued by + + + + NMi Certin B.V.,

designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable

requirements of Directive 2014/32/EU, to:

Manufacturer Elster Solutions GmbH

Steinern Straße 19-21 55252 Mainz-Kastel

Germany

Measuring instrument A static Active Electrical Energy Meter

Type : AS220 or AS253

Manufacturer's mark or name : Elster or Honeywell

Reference voltage : 230 V

Reference current : 5, 10 or 20 A

Destined for the measurement of : electrical energy, in a

- single-phase two-wire network

Accuracy class : A or B Environment classes : M1 / E2

Temperature range : $-40 \,^{\circ}\text{C} / +70 \,^{\circ}\text{C}$

Further properties are described in the annexes:

Description T10156 revision 6;Documentation folder T10156-3

Valid until 29 October 2018

Remarks This revision replaces the earlier versions, including its documentation

folder.

Issuing Authority NMi Certin B.V., Notified Body number 0122

5 March 2018

C. Oosterman

Head Certification Board

NMi Certin B.V.

Hugo de Grootplein 1 3314 EG Dordrecht The Netherlands T +31 78 6332332 certin@nmi.nl www.nmi.nl This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at http://ec.europa.eu/growth/tools-databases/nando/

Reproduction of the complete document only is permitted.

