

EU-type examination certificate

Number T10158 revision 23 Project number 2186518 Page 1 of 1

Issued by NMi Certin B.V.,

> designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable

requirements of Directive 2014/32/EU, to:

EMH metering GmbH & Co. KG Manufacturer

> Neu-Galliner Weg 1 D-19258 Gallin Germany

Measuring A static Active Electrical Energy Meter

Type : eHZ or EHZ

> Manufacturer's mark or name EMH metering

3x230/400V or 3x230V or Reference voltage

Reference current 5 A or 10 A (DCM: Direct connected

meter)

1 A (TCM: Transformer connected

meter)

Destined for the measurement of electrical energy, in a

> - three-phase four-wire network - single-phase two-wire network

- three-phase three-wire network

 $(I_{ref} = 5 A)$

A or B $(I_{ref} = 1 A \text{ or } I_{ref} = 10 A)$

three-phase three-wire network only

class A

Environment classes M2 / E2

Temperature range -40 °C / +70

Further properties are described in the annexes

Description T10158 revision 23;

Documentation folder T10158-1

Valid until 22 September 2028

This revision replaces the earlier versions, except for its documentation folder. Remarks

NMi Certin B.V., Notified Body number Issuing Authority

22 September 2018

Head Certification Board

NMi Certin B.V.

Hugo de Grootplein 1 3314 EG Dordrecht The Netherlands T+31 78 6332332 certin@nmi.nl www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party

The designation of NMi Certin B.V. as Notified Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/

Reproduction of the complete document only is permitted.

