

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Networked Energy Services
5215 Hellyer Avenue, Suite 150
San Jose, CA 95138
United States of America

Measuring instrument A static **Active Electrical Energy Meter**

Type	:	83331-3xxxx
Reference voltage	:	3x230/400 V
Reference current	:	5 or 10 A
Destined for the measurement of	:	electrical energy, in a <ul style="list-style-type: none">- three-phase four-wire network- two-phase three-wire network- single-phase two-wire network
Accuracy class	:	A or B
Environment classes	:	M2 / E2
Temperature range	:	-40 °C / +70 °C

Further properties are described in the annexes:
– Description T10166 revision 17;
– Documentation folder T10166-3.

Valid until 14 November 2028

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
12 March 2019



C. Oosterman
Head Certification Board