

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	ABB AB, Cewe-Control Arnöleden 2 SE-61129 Nyköping Sweden
Measuring instrument	A static Active Electrical Energy Meter Type : OD4165 (direct connected) or OD4110 (indirect connected) Reference voltage : 3x230/400 V Reference current : 5 or 10 A (direct connected) 5 A (indirect connected) Destined for the measurement of : electrical energy, in a - three-phase four-wire network Accuracy class : A or B Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes - Description T10168 revision 1 - Documentation folder T10168-1
Valid until	22 October 2018
Remarks	This revision replaces the earlier version, except for its documentation folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
9 June 2010


C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see www.nmi.nl).

Reproduction of the complete document only is permitted.