

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	Landis+Gyr 1 Lysander Drive, Northfields Industrial Estate, Market Deeping, Peterborough, PE6 8FB England
Measuring instrument	A static Active Electrical Energy Meter Type : (E450) ZCX110 and ZCX120 Reference voltage : 230 V Reference current : 5 A Destined for the measurement of : electrical energy, in a - single-phase two-wire network Accuracy class : A (ZCX120) or B (ZCX110) Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes: - Description T10225 revision 3; - Documentation folder T10225-3.
Valid until	19 January 2021
Remark	This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
2 December 2014


C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/enterprise/newapproach/nando/](http://ec.europa.eu/enterprise/newapproach/nando/)

Parties concerned can lodge
objection against this decision,
within six weeks after the date of
submission, to the general manager
of NMi (see www.nmi.nl).

Reproduction of the complete
document only is permitted.