

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Networked Energy Services  
5215 Hellyer Avenue, Suite 150  
San Jose, CA 95138  
United States of America

Measuring instrument A static **Active Electrical Energy Meter**  
Type : 83332-3lxxx  
Reference voltage : 3x230/400 V  
Reference current : 5 or 10 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- two-phase three-wire network  
- single-phase two-wire network  
Accuracy class : A or B  
Environment classes : M2 / E2  
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:  
- Description T10264 revision 17;  
- Documentation folder T10264-7.

Valid until 17 March 2030

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
17 March 2020

## Certification Board

**NMI Certin B.V.**  
Thijsseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.