

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Elster Rometrics S.R.L.
Sat Giarmata, Comuna Giarmata,
DJ 691 KM8+775M Dreapta,
Timisoara Airport Park, Judet Timis,
România

Measuring instrument A static **Active Electrical Energy Meter**

Type : A(S)1440-D1... (DC) or AS1440-W1... (CT)

Manufacturer's mark or name : Elster or Honeywell

Reference voltage : 3x230/400V or 3x230V (DC/CT)
3x58/100V or 3x100V (CT)
3x63/110V or 3x110V (CT)

Reference current : 5, 10 or 20 A (DC)
1, 2 or 5 A (CT)

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- single-phase two-wire network

Accuracy class : A or B (DC)
B or C (CT)

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
- Description T10326 revision 6;
- Documentation folder T10326-3.

Valid until 16 November 2020

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
21 December 2017


C. Oosterman
Head Certification Board