

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer SAGEMCOM ENERGY & TELECOM SAS
250 route de l'Empereur
92848 RUEIL MALMAISON CEDEX
France

Measuring instrument A static **Active Electrical Energy Meter**

Type : CX1000-6 SL (CX1000-6 EDP STREETLIGHTING) and CX1000-6 S

Manufacturer's mark or name : SAGEMCOM ENERGY & TELECOM SAS

Reference voltage : 127 V or 230 V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
– Description T10329 revision 18;
– Documentation folder T10329-8.

Valid until 29 November 2020

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
18 February 2019


C. Oosterman
Head Certification Board