




EC type-examination Certificate

Number **T10365** revision 0
Project number 11200254
Page 1 of 1

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	ELEKTROMED Elektronik San. ve Saglik Hizmetleri A.S. Organize Sanayi Bolgesi Buyuk Selcuklu Bulvari Uygurlar Cad. No:4 06935 - Sincan-Ankara Turkey
Measuring instrument	A static Active Electrical Energy Meter Type : EC25 Series Reference voltage : 3x230/400V (EC25TP.. and EC25TC..) 3x57,7/100V (EC25TV..) Reference current : 5 A Destined for the measurement of : electrical energy, in a - three-phase four-wire network Accuracy class : A, B or C Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes - Description T10365 revision 0 - Documentation folder T10365-1
Valid until	14 June 2021

Issuing Authority	NMi Certin B.V., Notified Body number 0122 14 June 2011  C. Oosterman Head Certification Board
-------------------	--

NMi Certin B.V. Hugo de Grootplein 1 3314 EG Dordrecht The Netherlands T +31 78 6332332 certin@nmi.nl www.nmi.nl	This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability. The designation of NMi Certin B.V. as Notified Body can be verified at http:// ec.europa.eu/enterprise/newapproach/nando/	Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see www.nmi.nl). Reproduction of the complete document only is permitted.	
---	---	---	---