

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of module B of Directive 2014/32/EU, to:
Manufacturer	BTicino SpA Viale Borri, 231 21100 - Varese (VE) Italy
Measuring instrument	A static <b>Active Electrical Energy Meter</b> Brands : IME, LGR, SCH, btc, SRK, MLR, NHP, HGR, SMS, or LAB Type : CE4DMID21, CE4DMID22, CE4DMID31, CE4DMID32, CE4DMID3M or CE4DMID3MBC Reference voltage : 3x190/328...3x277/480 V or 3x400 V or 3x230 V Reference current : 10 A Destined for the measurement of : electrical energy, in a - three-phase four-wire network - three-phase three-wire delta network Accuracy class : A or B Environment classes : M1 / E2 Temperature range : -25 °C / +55 °C Further properties are described in the annexes: - Description T10368 revision 7; - Documentation folder T10368-6.
Valid until	22 August 2021
Remark	This revision replaces the earlier versions, including its documentation folder.
Issuing Authority	<b>NMi Certin B.V., Notified Body number 0122</b> 3 December 2018



C. Oosterman  
Head Certification Board