


Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	MAK-SAY Elektrik ve Elektronik Mlz.San.Tic.A.Ş. İstiklal Mah. Maraşal Fevzi Çakmak Cd. No:40 Kıracı 34522 Esenyurt İstanbul Turkey
Measuring instrument	A static Active Electrical Energy Meter Type : T500 Family Reference voltage : 3x220/380V Reference current : 5 A for both direct and indirect connected variants Destined for the measurement of : electrical energy, in a - three-phase four-wire network Accuracy class : A or B Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes - Description T10369 revision 0 - Documentation folder T10369-1
Valid until	10 August 2021

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
10 August 2011



C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see www.nmi.nl).

Reproduction of the complete document only is permitted.