

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity modules mentioned in article 9 of Directive 2004/22/EC, after
having established that the Measuring instrument meets the applicable
requirements of Directive 2004/22/EC, to:


Manufacturer Itron Indonesia - PT Mecoindo
EJIP Plot 6B-2 Lemah Abang,
17550 – Bekasi
Jawa Barat - Indonesia

Measuring instrument A static **Active Electrical Energy Meter**
Type : ACE2000 - Type 351
Reference voltage : 230 V
Reference current : 5 A or 10 A
Destined for the measurement of : electrical energy, in a
- single-phase two-wire network
Accuracy class : A or B
Environment classes : M2 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes
– Description T10383 revision 0
– Documentation folder T10383-1

Valid until 22 August 2021

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
22 August 2011



C. Oosterman
Head Certification Board

NMI Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
applicant shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/enterprise/newapproach/nando/](http://ec.europa.eu/enterprise/newapproach/nando/)

Parties concerned can lodge
objection against this decision,
within six weeks after the date of
submission, to the general manager
of NMI (see www.nmi.nl).

Reproduction of the complete
document only is permitted.