

EC type-examination Certificate

Number **T10394** revision 1
Project number SO13200102
Page 1 of 1

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	KOHLER ELEKTRIK SAYACLARI SAN.TIC.A.S. Akcaburgaz Mah. 58.Sok. No:3 Esenyurt 34510 Istanbul Turkey
Measuring instrument	A static Active Electrical Energy Meter
	Type : AEL.TF.25 as transformer connected meter (TCM) AEL.TF.22 and AEL.TF.23 as direct connected meter (DCM)
	Reference voltage : 3x230/400V
	Reference current : 1 A (TCM) 5 A (DCM)
	Destined for the measurement of : electrical energy, in a - three-phase four-wire network
	Accuracy class : A or B
	Environment classes : M1 / E2
	Temperature range : -40 °C / +70 °C
	Further properties are described in the annexes - Description T10394 revision 1 - Documentation folder T10394-2
Valid until	31 October 2021
Remarks	This revision replaces the earlier versions, including its documentation folder.
Issuing Authority	NMi Certin B.V., Notified Body number 0122 18 January 2013

C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see www.nmi.nl).

Reproduction of the complete document only is permitted.