


| | |
|----------------------|--|
| Issued by | NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to: |
| Manufacturer | Shenzhen Kaifa Technology (Chengdu) Co., Ltd. No.1218 Hezuo Rd., Hi-Tech Development Zone (West), Chengdu, P.R. China |
| Measuring instrument | A static Active Electrical Energy Meter Type : MA105 Manufacturer's mark or name : Kaifa Reference voltage : 230 V Reference current : 5 A Destined for the measurement of : electrical energy, in a - single-phase two-wire network Accuracy class : A or B Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes: - Description T10420 revision 6; - Documentation folder T10420-7. |
| Valid until | 20 July 2022 |
| Remarks | This revision replaces the earlier versions, including its documentation folder. |

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
14 October 2016



C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Reproduction of the complete document only is permitted.