

EC type-examination Certificate

Number **T10427** revision 0
Project number SO 11200995
Page 1 of 1

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity modules mentioned in article 9 of Directive 2004/22/EC, after
having established that the Measuring instrument meets the applicable
requirements of Directive 2004/22/EC, to:

Manufacturer Enerdis s.a.s.
16, rue Georges BESSE
SILIC 44
92182 ANTONY Cedex
France

Measuring instrument A static **Active Electrical Energy Meter**

| | | |
|---------------------------------|---|---|
| Type | : | MD65-M |
| Reference voltage | : | 220, 230 or 240 V |
| Reference current | : | 10 A |
| Destined for the measurement of | : | electrical energy, in a single-phase two-wire network |
| Accuracy class | : | A or B |
| Environment classes | : | M1 / E2 |
| Temperature range | : | -40 °C / +70 °C |

Further properties are described in the annexes
– Description T10427 revision 0
– Documentation folder T10427-1

Valid until 23 November 2021

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
23 November 2011



C. Oosterman
Head Certification Board

NMI Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
applicant shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/enterprise/newapproach/nando/](http://ec.europa.eu/enterprise/newapproach/nando/)

Parties concerned can lodge
objection against this decision,
within six weeks after the date of
submission, to the general manager
of NMI (see www.nmi.nl).

Reproduction of the complete
document only is permitted.