

EU type-examination certificate

Number **T10437** revision 14 Project number SO16203741 Page 1 of 1

Issued by NMi Certin B.V.,

designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable

requirements of Directive 2014/32/EU, to:

Manufacturer Itron

1 Avenue des temps modernes

ZI du Bernais B.P. 23

86361 Chasseneuil du Poitou

France

Measuring instrument A static Active Electrical Energy Meter

Type : SL7000 series

Reference voltage + + + + + : 3x57,7/100 V... 3x277/480 V Reference current + + + + + + : transformer connected (CT): 1 A

direct connected (DC): 5 A or 20 A

Destined for the measurement of : electrical energy, in a

three-phase four-wire networkthree-phase three-wire network

Accuracy class : B or C (CT)

A or B or C (DC)

Environment classes + + + + : M2 / E2

Further properties are described in the annexes:

Description T10437 revision 14;Documentation folder T10437-6

Valid until + + + + 29 May 2022

Remarks This revision replaces the earlier versions, including its documentation

folder.

Issuing Authority NMi Kertin B.V., Notified Body number 0122

14 October 2016

C. Øosterman

Head Certification Board

NMi Certin B.V. Hugo de Grootplein 1 3314 FG Dordrecht

Hugo de Grootpiein 3314 EG Dordrecht The Netherlands T +31 78 6332332 certin@nmi.nl This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at http://ec.europa.eu/enterprise/newapproach/nando/

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see www.nmi.nl).

Reproduction of the complete document only is permitted.

