

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity modules mentioned in article 17 of Directive 2014/32/EU, after
having established that the Measuring instrument meets the applicable
requirements of Directive 2014/32/EU, to:

Manufacturer Itron Indonesia - PT Mecoindo
EJIP Plot 6B-2 Lemah Abang,
17550 – Bekasi
Jawa Barat - Indonesia

Measuring instrument A static **Active Electrical Energy Meter**
Type : EM211 type 100

Reference voltage : 120 V, 220 V, 230 V or 240 V

Reference current : 10 A or 20 A

Destined for the measurement of : electrical energy, in a
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes
– Description T10450 revision 2
– Documentation folder T10450-3

Valid until 23 May 2032

Remarks This revision replaces the earlier version(s), including its documentation
folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
6 October 2022

Certification Board

NMI Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
applicant shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.

Reproduction of the complete
document only is permitted.