

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer SAGEMCOM ENERGY & TELECOM SAS  
250 route de l'Empereur  
92848 RUEIL MALMAISON CEDEX  
France

Measuring instrument **A static Active Electrical Energy Meter**

Type : CX2000-9

Reference voltage : 3x127/220V or 3x230/400V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network

Accuracy class : A or B

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:  
- Description T10465 revision 47;  
- Documentation folder T10465-13.

Valid until 31 July 2032

Remark This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
05 January 2023

## Certification Board

**NMI Certin B.V.**  
Thijssseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.