



# EC type-examination Certificate

Number **T10559** revision 0  
Project number SO13200844  
Page 1 of 1

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of module B of Directive 2004/22/EC, to:
Manufacturer	Legrand GmbH D 59494 Soest Am Silberg 14 Germany
Measuring instrument	A static <b>Active Electrical Energy Meter</b> Type : 046 82 or 046 83 Reference voltage : 3x190/328...3x277/480V Reference current : 10 A Destined for the measurement of : electrical energy, in a - three-phase four-wire network Accuracy class : A or B Environment classes : M1 / E2 Temperature range : -25 °C / +55 °C Further properties are described in the annexes – Description T10559 revision 0 – Documentation folder T10559-1
Valid until	18 April 2023

Issuing Authority **NMi Certin B.V., Notified Body number 0122**  
18 April 2013

C. Oosterman  
Head Certification Board

**NMi Certin B.V.**  
Hugo de Grootplein 1  
3314 EG Dordrecht  
The Netherlands  
T +31 78 6332332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The designation of NMi Certin BV.as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see [www.nmi.nl](http://www.nmi.nl)).

Reproduction of the complete document only is permitted.

